

INSERT PAGES  
IBC CHAPTER 6

To be inserted between pages 86 & 87

**Comm 62.0603 Allowable materials.** Substitute the following wording for application 18 in IBC section 603.1: Sprayed fire-resistant materials and intumescent and mastic fire-resistant coating, determined on the basis of fire-resistance tests in accordance with Section 703.2